

Tender text

PE100 fittings for hydrants (cross, X cross, service line connection distributor)

General preliminary remark

The fittings to be offered must be manufactured from material in compliance with the PE100+ Association and according to DIN EN 12201 with respect to dimensions, tolerances and quality requirements. Proof must be provided that they were manufactured on the basis of a quality assurance system in accordance with DIN EN ISO 9001. For all fittings a certificate in accordance with DIN EN 10204 must be submitted by the manufacturer. The body of the fitting must be manufactured from a piece of homogeneous semi-finished material so as to ensure the required reinforcement and therefore high stability of the fitting. Semi-finished materials manufactured from wound rods or the subsequent application of other forms of reinforcing are not permitted.

The spigots must have a long shape to enable both HE butt welding and HW welding.

The flange connections must be implemented with the same nominal diameter according to DN 80 or DN 100 in compliance with DIN EN 1092-1 and have an outwardly reinforced weld seam area designed for the hydrant load; DN 80 -> 110 mm outer diameter as well as DN 100 -> 135 mm outer diameter.

The backing flange is manufactured from corrosion-free, fibre-reinforced plastic, supports the PE stub from outside and provides a plate spring function that maintains the pretension after the bolts have been tightened.

Optionally available versions: Flange with O-ring seal, socket for spigot or for hydrant at the outlet

Standards/guidelines

DIN EN 12201, DIN EN 1092-1, DVS 2207, DVS 2210, DIN EN 10204, DIN EN ISO 9001, DIN EN ISO 50001, DVGW W 400-2, DVGW GW 335

Permits/certificates

Acceptance test certificate 3.1 according to DIN EN ISO 10204 for the semi-finished material from the processed raw material with indication of MFR and OIT; only PE100 material in compliance with PE100+ Association

Manufacturer certified according to ISO 9001:2015 and ISO 50001:2011

Manufacturer:

Reinert-Ritz GmbH or equivalent

Performance specification:

1. PE100 cross for connection to hydrant, reinforced design, with special flange connection (VP flange) of the same nominal diameter and with a fibre-reinforced backing flange at the outlet, drilled according to DIN EN 1092-1, with spring effect for continuous bolt preload, long welding ends for HW welding, d1 ... / DN ... SDR ...

2. PE100 X-cross for connection to hydrant, reinforced design, with special flange connection (VP flange) of the same nominal diameter and with a fibre-reinforced backing flange at the outlet , drilled according to DIN EN 1092-1, with spring effect for continuous bolt preload, long welding ends for HW welding, d1 ... / DN ... SDR ...
3. PE100 service line connection distributor with four connection options, reinforced design with extra long service line connecting pieces and three blind plugs with an EPDM O-ring, suitably drilled according to DIN EN 1092-1, sealing surface with EPDM O-ring, n x d1 ... / DN ... SDR ... | n x d3 ... / DN ... SDR ...

Proof of delivery:

Reinert-Ritz GmbH
Ernst-Heinkel-Straße 2
48531 Nordhorn
Tel.: +49 5921 8347-0
Fax: +49 5921 8347-25
www.reinert-ritz.de
Email: contact@reinert-ritz.com