

Tender text

PE100 tee with flange outlet, long, for HW welding

General preliminary remark

The fittings to be offered must be manufactured from material in compliance with the PE100+ Association and according to DIN EN 12201 with respect to dimensions, tolerances and quality requirements. Proof must be provided that they were manufactured on the basis of a quality assurance system in accordance with DIN EN ISO 9001. For all fittings a certificate in accordance with DIN EN 10204 must be submitted by the manufacturer. The body of the fitting must be manufactured in the injection moulding process or alternatively, in the case of more complex structures, from a piece of homogeneous semi-finished material so as to ensure the required reinforcement and therefore high stability of the fitting. Semi-finished materials manufactured from wound rods or the subsequent application of other forms of reinforcing are not permitted.

At the outlet PE100 flange connections in the run pipes, pipe pieces of the same quality must be welded on according to the HE butt welding procedure; inner beads of up to d 630 mm must be removed.

The flange connections must be pressure class-compatible and the hole pattern must comply with DIN EN 1092-1 PN 10 or PN 16. Depending on the mating flange type, the flange outlet must be designed as an HP flange or a special flange with the same nominal diameter.

The backing flanges must be manufactured from corrosion-free, fibre-reinforced plastic or from steel with a plastic coating in accordance with DIN EN 10310.

Optionally available versions: Design according to DIN EN 1092-1 PN 25, stainless steel backing flange, galvanised backing flange, flat sealing without groove and O-ring or with long holes in the PE stub for perfect alignment of the accessories to be connected.

Standards/guidelines

DIN EN 12201, DIN EN 1092-1, DVS 2207, DVS 2210, DIN EN 10204, DIN EN ISO 9001, DIN EN ISO 50001, DVGW W 400-2, DVGW GW 335

Permits/certificates

Acceptance test certificate 3.1 according to DIN EN ISO 10204 for the semi-finished material from the processed raw material with indication of MFR and OIT; only PE100 material in compliance with PE100+ Association

Manufacturer certified according to ISO 9001:2015 and ISO 50001:2011

Manufacturer:

Reinert-Ritz GmbH or equivalent

Performance specification:

PE100 tee with flange outlet, pressure class-compatible, long for HW welding, drilled according to DIN EN 1092-1,

Run pipe d1: d ... SDR ...

Outlet d2: d ... SDR ... /DN ... PN ...



Proof of delivery:

Reinert-Ritz GmbH
Ernst-Heinkel-Straße 2
48531 Nordhorn
Tel.: +49 5921 8347-0
Fax: +49 5921 8347-25
www.reinert-ritz.de
Email: contact@reinert-ritz.com